



rfo-sfps-rajkot@gujarat.gov.in



**FORM B 13.3**  
**FIRE SAFETY CERTIFICATE RENEWAL (FSCR)**  
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFORAJ/2025/00123374  
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFORAJ/2025/00123374/R1

Date: 10/06/2025

Building Occupancy/Category: Educational (non-residential)

To,

Gandhidham Matri Mandal  
Plot No. 659/660, Ward 12C, Lilashah Nagar, Gandhidham, Kutch, Gujarat - 370201  
Fire Region: Rajkot RFO  
Mobile No: 9408530300 Email ID: gmm.gim@gmail.com

We have received Application No. **2025/00123727** dated 21/05/2025 for Fire Safety Certificate Renewal (FSCR) - New Building (FSCR)/Existing Building (FSCRe) for the building/premise **GANDHIDHAM MATRI MANDAL (name of the Building/ Project)**, as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: GANDHIDHAM
5. Name of Block(s): GANDHIDHAM MATRI MANDAL

The building/premise was inspected on **10/06/2025** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **10/06/2025**
2. Six monthly inspection was done on **10/06/2025**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **10/06/2027** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated: **10/06/2025 10:25:35 AM**



**Digitally Verified**

Digitally verified by: Dipen Rajendrabhai Hansora  
Fire Safety Officer - General (FSO-G)  
2021/001355  
Reviewed by : RFO Rajkot  
Date: 10/06/2025  
Time: 10:25 AM



FSCA/O/RFORAJ/2025/00123373/R1

*This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).*

*Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.*